Annexure C

Appendix-XIII

Dated: 09/11/2023

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by Mr. Sumit Stivestava (S.E.) & Team (Name of Officers with designation) from U.P. Jal Nigam (Ruxal) Jaumpur (Name of Department/ Office) inspected the City International School Pilkichha, (Name & Address of the school) on \(\Omega \). (date of inspection), checked the water test report

submitted by the school and found that the school has potable drinking water for students and staff of the

institution and is having provision for running water in the toilets and maintaining hygienic sanitation

condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of ...O.I. Year

No. Memo / School /02

अधिशासी अभियन्ता Signature with Seal:্ড্ৰ্যাভ্ৰ.ক্রায়ার

Designation: Junior Eng.

Assistant Engineer of the Govt. Public Health Department (PHED)/ Authorised officer of the Local Body

Name & Address of the Office / Department :

To Principal City International School City International salves

Silent अभियन्ता

Bilkichha, Khuthan, Saung

खण्ड कार्यालय

जत्तर प्रदेश जल निगम (प्रामीण)

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



Water Analysis Report District, Jaunpur

Rept No .				Date	06/11/2023	Page No	
NO			Cı	ustomer Deta	ils		
Office	Name and Address	City Intern	ational Schoo	l, Pilkichha (Khu	ıthan), Jaunpur Pin-22	3104	
Ref Le	etter No. & Date	14/2023					
			Basic	c details of sa	mple		
Distri	ct	Jaunpur			Block	Khuthan	
Gram Panchayat		Pilkichha			Village	Pilkichha	
Habitation					Location	Pilkichha (Khuthan), Jaunp	
		R O Water			Sample No.	Sample 1	
Water Source					Date of S.C.	03/11/2023	
Quality of Sample		1000ml (Normal)			S. Collector	Mr. Rajeev Yadav	
Receiving Date		03/11/2023			S. Collector	WII. Najec	v Tauav
Samp	e Depositor	Mr. Rajeev Yadav				04/11/2022	
Analysis Start Date		04/11/2023			Analysis Completion Date 04/11/2023		
			Techni	ical Data of Ar	nalysis		
SR	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS		Def Method of Analysis		
			Acceptable Limit	Permissible Limit	Ref. Method of Analysis		
1	2	<u>3</u>	4	<u>5</u>	6		
1	рН	7.31	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 1983:2021(Electrometric Method)		
2	Turbidity (NTU)	0.59	1.00	5.00	IS 3025 (Part 10): 1984:2021(Nephelometer Method)		
3	TDS. Mg/1	223	500	2000	IS 3025 (Part 16): 1984:2021(Gravimetric Method)		
4	Chloride (as CI), mg/1	10	250	1000	IS 3025 (Part 32): 1988:2021(Titration Method)		
5	Total Alkalinity (as Na2CO3), mg/1	188	200	600	IS 3025 (Part 23): 1986:2021(Titration Method)		
6	Total Hardness (as CaCO3), mg/1	92	200	600	IS 3025 (Part 21): 2009:2021(Titration Method)		
7	Calcium (as Ca), mg/1	16.8	75	200	IS 3025 (Part 40): 2019		
8	Magnesium (as Mg), mg/1	12.5	30	100	IS 3025 (Part 46): 2019		
9	Nitrate (as NO3), mg/1	5	45	No Relaxation	APHA 23rd Ed 2017, 4500-NO3 (B.Ultraviolet Spectrophotometric Screening Method		
10	Fluoride (as F), mg/1	0.324	1.00	1.5	APHA 23rd Ed 2017, 4500-F (C. Ion Selection Electrode Method)		
11	Iron (as Fe), mg/1	1.00	1.00	No Relaxation	APHA 23rd Fd 2017, 3500-Fe (B Phenanthroline Method)		
12	Residual Chlorine	0.2	NA	0.2	IS 3025 (Part 26): 2021		
13	Total Coliform (MPN/100mL)	0	NA	0.0	IS 1622		

Note-

This Certificate refers only to the particular sample(s) submitted for testing.

This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.

The test result reported in this certificate is valid at the time of and under the stated conditions of measurements.

Sample will be stored up to 15 days (in case of non-perishable items only) from the date of issue of tests reports unless otherwise specified.

red signator

Kymar mohit Prepare by

अधिशासी अभियन्ता खण्ड कार्यालय उत्तर प्रदेशं जल निगम (ग्रामीण) जोनपुर

Lab Technician